



3) EXTEND ALL CPLGS. 5/8" INSIDE.
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	LEFT-.248" SA-455 2:1 S.E. (.186" MIN.)	CS-56-1225-H	REV. 4-22-03
	RIGHT-.248" SA-455 2:1 S.E. (.206" MIN.)		DATE: 10-4-89
	FOR: HANSON STANDARD		
	HORIZ. WATER TANK		
SHELL	.218" SA-455	165.1 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
	M.A.W.P. 125 PSIG. @ 210 °F	INSIDE: CEMENT LINED (1180)	
ASME. SECTION IV 2001 ADD 2002		OUTSIDE: PRIME	
X-RAY: RT-NO / H.L.W.		CAD-"B" UNDER "STD"-SERIES	
GALLONS: 1225		WT. 2952 LBS.	
SERIAL NO.		BY: E.S. SCALE: 3/4"=12"	
N.B.		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	