



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) EXTEND ALL CPLG. 5/8" INSIDE.
 3) HYDRO @ 240 PSIG. MIN.
 4) 4-1-04 PROOF TEST.

HEADS	.166" SA-414-G 2:1 S.E.	CS-30-140-V	REV. 10-12-04
	JOGGLE		DATE: 3-31-03
SHELL	.165" SA-414-G	FOR: HANSON STANDARD VERT. HOT WATER TANK	
	M.A.W.P. 160 PSIG. @ 210 °F	37.1 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2001 ADD 2003		INSIDE: CEMENT LINED	
X-RAY: RT-NO/H.L.W.		OUTSIDE: PRIME	
GALLONS: 140	WT. 610 LBS.	(129) LEG-ZONE 4-15 KM.	
SERIAL NO.		CAD-"B" UNDER "STD"-SERIES	
N.B.		BY: J.G.	SCALE: 1"=12"
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	