



4) 4-1-04 PROOF TEST.  
 3) HYDRO @ 240 PSIG. MIN.  
 2) EXTEND ALL CPLGS. 5/8" INSIDE.  
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	.182" SA-455 2:1 S.E.	CS-36-400-V	REV. 10-6-04
	JOGGLE		DATE: 8-12-98
SHELL	.166" SA-414-G	FOR: HANSON STANDARD	
	(.164" MIN.)	VERT. HOT WATER TANK	
M.A.W.P. 160 PSIG. @ 210 °F		99.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2001 ADD 2003		INSIDE: CEMENT LINED	
X-RAY: RT-NO / H.L.W.		OUTSIDE: PRIME	
GALLONS: 400	WT. 1394 LBS.	(379) LEG-ZONE 4-15 KM.	
SERIAL NO.		CAD-"B" UNDER "STD"-SERIES	
N.B.		BY: E.S.	SCALE: 1"=12"
		<b>ROY E. HANSON JR. MFG.</b>	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	