



NOTE. 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 240 PSIG.
 3) EXTEND ALL CPLG'S 5/8" INSIDE.
 4) 4-1-04 PROOF TEST.

SHELL / HEADS	.205" SA-455 2:1 S.E.	CS-42-462-V	REV. 10-7-04
	JOGGLE		DATE: 10-10-90
SHELL / HEADS	.175" SA-414-G	FOR: HANSON STANDARD	
		VERT. HOT WATER TANK	
M.A.W.P.	160 PSIG. @ 210 °F	82.8 SQ. FT. SURFACE AREA.	
ASME. SECTION IV	2001 ADD 2003	THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
X-RAY:	RT-NO / H.L.W.	INSIDE: CEMENT LINED	
GALLONS:	462	OUTSIDE: PRIME	
SERIAL NO.		(431) LEG ZONE: 4-15 KM.	
N.B.		CAD "B" UNDER "STD"-SERIES	
		BY: J.G.	SCALE: 3/4"=12"
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	