



- 4) 4-22-04 PROOF TEST.
- 3) EXTEND ALL CPLGS. 5/8" INSIDE.
- 2) HYDRO @ 240 PSIG.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

SHELL / HEADS	.245" SA-36 2:1 S.E.	CS-48-712-V	REV. 10-7-04
	JOGGLE		DATE: 3-27-03
SHELL / HEADS	.200" SA-455	FOR: HANSON STANDARD	
		VERT. HOT WATER TANK.	
M.A.W.P.	160 PSIG. @ 210 °F	113.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION	IV 2001 ADD. 2003	INSIDE: CEMENT LINED	
X-RAY:	RT-NO / H.L.W.	OUTSIDE: PRIME	
GALLONS:	712	WT. 1986 LBS.	(680) LEG-ZONE 4-15 KM.
SERIAL NO.			CAD-"B" UNDER "STD"-SERIES
N.B.			BY: J.G. SCALE: 3/4" = 1'
		ROY E. HANSON JR. MFG.	
		1924 COMPTON AVE. LOS ANGELES, CA 90011	